



ಮೈಸೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ,
ನ್ಯೂ ಸಯ್ಯಾಜಿರಾವ್ ರಸ್ತೆ,
ಮೈಸೂರು 570024



MYSURU CITY CORPORATION
New Sayyaji Rao Road
Mysuru 570024



Ph: 0821-2418803, comm.mysurucitycorporation@gmail.com, www.mysorecity.mrc.gov.in

No.H3PR/60/2023-24

Date: 05-02-2024

ANNEXURE-C

PROFORMA FOR SAFE DRINKING WATER AND SANITATION CONDITION CERTIFICATE

It is certified that an inspection team headed by Corporation Health Officer, Mysuru City Corporation, Mysuru inspected the KAVERI VIDYA SAMSTHE H.S., SR-1, Jayanagar Connecting Saraswatipuram, T.Koppal, K-Block, Kuvempunagara, MYSORE-570023 on 03-02-2024 and on the basis of Water Test Report bearing No. MYS24DD176 Dated: 19-01-2024 of Rural Drinking Water and Sanitation Division, Mysuru District Water Quality Testing Laboratory certified that the KAVERI VIDYA SAMSTHE H.S., SR-1, Jayanagar Connecting Saraswatipuram, T.Koppal, K-Block, Kuvempunagara, MYSORE-570023 has safe drinking water facilities for the Students and members of staff of the institution. School is also maintains the Hygiene Sanitation conditions in the school building and the campus are as per the norms prescribed by the Central /State/U.T. Govt., The certificate is valid for a period of One year.

venkatesh
Corporation Health Officer
Mysuru City Corporation
Mysuru City Corporation
Mysuru
Mysuru

To,

CHAIRMAN
KAVERI VIDYA SAMSTHE H.S., SR-1,
Jayanagar Connecting Saraswatipuram,
T.Koppal, K-Block, Kuvempunagara,
MYSORE-570023

[Signature]
PRINCIPAL

KAVERI VIDYA SAMSTHE HS
KUVEMPUNAGAR, MYSORE-570 023

[Signature]
CHAIRMAN
KAVERI VIDYA SAMSTHE H S
Kuvempunagar, MYSURU-570023



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
RURAL DRINKING WATER & SANITATION DIVISION, MYSURU
Mysuru District Water Quality Testing Laboratory, Room No. 05, Zilla Panchayath
Premises, Near Law Court, Chamaraajapuram Mohalla, Lakshmiapuram,
Mysuru - 570005. e-mail: rdwsd.wqmisp.mysore@gmail.com

TEST REPORT

Address of the sampling location/Name & address of the customer if any : Location : Kaveri vidya samsthe H S SR-01 Jayanagara connecting saraswathipuram T koppal K block kuvempunagara Mysuru				Report Date: 20/01/2024	
				Report Number: MYS24DD176	
				Reference: Test Request Form	
				Sample receipt date: 19/01/2024	
				Sample code: MYS24DD176	
				Date of Sample collection: 19/01/2024	
				Analysis start date: 20/01/2024	
				Analysis completion date: 20/01/2024	
Sample collection protocol: RDWSD/WQMSP/SOP/23				Sample Quantity: 1Liter	
Sample Particulars: Borewell water					
SLN o	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless Liquid					
1.	pH Value @ 25.5°C	7.7	6.5 - 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, $\mu S/cm$ @ 25.5°C	152	-	-	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021 Platinum Cobalt(Visual Comparison M
5.	Turbidity, NTU	0.5	1	5	IS 3025 (Part-10) : 1984
6.	Total Dissolved Solids@180°C, mg/l	94	500	2000	IS 3025 (Part-16) : 1984
7.	Alkalinity as $CaCO_3$, mg/l	24.24	200	600	IS 3025 (Part-23) : 1986
8.	Total Hardness as $CaCO_3$, mg/l	32.35	200	600	IS 3025 (Part-21) : 2009(5 EDTA metho
9.	Calcium as Ca, mg/l	8.10	75	200	IS 3025 (Part-40) : 1991(5 EDTA Titrim method)
10.	Magnesium as Mg, mg/l	< 5.0	30	100	IS 3025 (Part-46) : 1994(6 Volumetric analysis using EDTA)
11.	Chloride as Cl, mg/l	18.12	250	1000	IS 3025 (Part-32) : 1988(Argentometri method)
12.	Sulphate as SO_4 , mg/l	22.25	200	400	IS 3025 (Part-24) : 2022(4 Turbidity m
13.	Fluoride as F, mg/l	0.64	1	1.5	APHA 24th Edition, 4500-F: D
14.	Nitrate as NO_3 , mg/l	2.15	45	No relaxation	APHA 24th Edition, 4500-NO3 -B
15.	Iron as Fe, mg/l	0.11	1	No relaxation	IS 3025 (Part-53) : 2003(6 1,10 Phenanthroline method)
Remarks: The above tested Physical & Chemical parameters conforms to the Acceptable limit of IS 10500:2012 Drinking water specification for the given sample only .					
Analysed by: Sangeetha U Senior Analyst <i>Sangeetha U</i>				Authorized Signatory: Sangeetha U Technical Manager <i>Sangeetha U</i>	

RDWSD/WQMSP/TeR/01

Senior Analyst cum Technical
Mysuru District Labor
Rural Drinking Water & S
Division, Mysuru

[Signature]
CHAIRMAN
KAVERI VIDYA SAMSTHE H S
Kuvempunagar, MYSURU-570023

[Signature]
PRINCIPAL

KAVERI VIDYA SAMSTHE HS
KUVEMPUNAGAR, MYSORE-570 023

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

**** End of Report ****